

BPI 7 Quart Ultrasonic Cleaner™

For use only by qualified personnel in a laboratory environment.

Due to high operating temperature, access should be restricted.

CAUTION

DO NOT IMMERSE UNIT.
DO NOT ALLOW ANY LIQUID INTO INTERIOR OF UNIT.
This can void your warranty.

About Your BPI Cleaner

The BPI Ultrasonic Cleaner is the only such system with multi-oscillator cleaning and Multi-Phasic™ power pulses which provide random-sized bubbles with no standing waves. It will give best results for general cleaning when used with BPI Ultrasonic 'C'™, which has special chemical abilities that sequester ionic residue and may be used in most all cleaning applications.

For optimum cleaning, it is most important to fill the tank to the correct level to ensure proper frequency resonance. An optional immersion carrier is available for general parts cleaning.

For use only by qualified personnel in a laboratory environment. Do NOT allow any personal contact with ultrasonic energy.

Specifications

Your High Power Cleaner has a non-removable stainless steel tank contained in an aluminum chassis. The Cleaner requires 115 volts, 60 Hz unless otherwise ordered. (Cleaners are also available by special order in 220 volt models.)

HEIGHT	WIDTH	LENGTH	VOLTAGE	WEIGHT	OPTIONS
10 in.	13.75 in.	14.25 in.	115 v.or 220 v.		
254 mm	350 mm	362 mm			
TANK DEPTH	TANK WIDTH	TANK LENGTH	TANK CAPACITY	PEAK POWER	SET-UP KIT
3.75 in.	11.5 in.	9 in.	1¾ Gallons	500 watts	1 Lid Instruction manual
95 mm	292 mm	228 mm	6.62 Liters		

Unpacking

When unpacking your ultrasonic cleaner, please check to ensure that no concealed damage occurred in transit. If such is noted, save the shipping carton and immediately notify the shipping company's damage control inspector in your area so a claim may be processed. Failure to do this may void any future claim and replacement. Also, call BPI Customer Service so arrangements for a replacement may be made.

Notes

- NEVER turn the ultrasonic on when tank is empty as PERMANENT DAMAGE may result. The tank should be at least ¾ full of water or diluted Ultrasonic "C" solution when the instrument is on.
- Always UNPLUG unit from power source before filling tank.
- DO NOT immerse hands in cleaning solution while unit is in operation.
- NEVER remove ground prong from power plug as it ensures safe electrical operation.
- Ultrasonic energy generates heat in the solution. You should periodically check the item(s) being cleaned to avoid unnecessary thermal exposure. Use caution when immersing hand.

General Cleaning

- Fill tank with tap water approximately 2" from the top; wipe excess water from the cabinet and work area and plug in the power cord.
- Add BPI Ultrasonic 'C'™ cleaning concentrate to water in tank.
- Place items to be cleaned in tank.
- Turn on ultrasonic switch. For full cleaning power, re-circulation should be off. Solution can be filtered (cleaned) by turning on re-circulation periodically.
- For most cleaning operations, 1-3 minutes is sufficient; more difficult jobs will require proportionately longer times. You will notice that the Cleaner will not harm the thinnest gold platings.
- When the cleaning is completed, turn off all power switches; remove cleaned items promptly.
- If cleaning jewelry, do NOT place pearls or opals in the Cleaner. While other gems may be cleaned in the Cleaner, BPI assumes no liability for these items.

Questions?..

If you have any questions about the use of your Ultrasonic Cleaner or need technical product information, call the BPI Research Department. For information about any other BPI product and to order supplies, please give us a toll-free call at the number for your area.

BPI 7 Quart
Ultrasonic
Cleaner™